

**From:** FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>

**Sent:** 07 July 2025 15:34

**To:** Meg.Bayliss [REDACTED]

**Subject:** RE: FW: DC/25/0040

Hi Meg,

The plans submitted do show the measurement to the furthest points within the dwelling via the hose lay route and indicates all are within 45m, therefore the Approved Document B Volume 1 B5 requirements have been met and the consultation raised has been answered and conditions met.

Regards

Ian



**Ian Stocks**

Water & Access Manager - Protection

**West Sussex Fire & Rescue Service**

**Office** 0330 222 4499 [REDACTED]

**Web** [www.westsussex.gov.uk/fire](http://www.westsussex.gov.uk/fire)

**Email** [frs.waterandaccess@westsussex.gov.uk](mailto:frs.waterandaccess@westsussex.gov.uk)

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

**My pronouns are he/him/his** 🏳️‍🌈

[Click here to find out why we use pronouns in our signatures](#)

