



Horsham
District
Council

HORSHAM DISTRICT COUNCIL CONSULTATION

TO:	Horsham District Council – Planning Dept
LOCATION:	The Slips West End Lane Henfield
DESCRIPTION:	Change of use of the land for the stationing of 4no. gypsy and traveller static caravans for residential purposes and 5no. associated dayrooms.
REFERENCE:	DC/25/1700
RECOMMENDATION:	More Information
SUMMARY OF COMMENTS & RECOMMENDATION: Recommended condition to cover aspects of drainage to the site	
MAIN COMMENTS: <ul style="list-style-type: none">• The proposed Static caravans are all too close to the boundary – they need to be 3 metres minimum for fire safety• More information is needed as to where the treatment plant will be located, how often it will be emptied and treated, where the ditch is located, where it will flow to and does it have the capacity and flow to absorb the treated effluent.• There is potential for nuisance from light to neighbours. We would recommend details of proposed lighting to be provided to the local Planning authority	
ANY RECOMMENDED CONDITIONS: When further information has been provided, appropriate conditions can be provided	
NAME:	Kendra Barrington
DEPARTMENT:	Environmental health and Licensing
DATE:	10 November 2025