



TANK CODE	CAPACITY	'A'	'B'	'C'	'D'	'E'
PW1.0	1000	1440	1000	1350		
PW2.0	2000	1969	1200	1550		
PW3.0	3000	2853	1200	1550		
PW4.0	4000	2510	1500	1850		
PW5.0	5000	3070	1500	1850		
PW6.0	6000	3640	1500	1850		
PW7.0	7000	4202	1500	1850		
PW8.0	8000	4768	1500	1850		
PW9.0	9000	5344	1500	1850		
PW10.0	10000	5900	1500	1850		
PW12.0	12000	5016	1800	2100		
PW14.0	14000	5800	1800	2100		
PW16.0	16000	6588	1800	2100		
PW18.0	18000	4118	2500	2500		
PW20.0	20000	4525	2500	2800		
PW22.0	22000	4910	2500	2800		
PW25.0	25000	5544	2500	2800		
PW27.0	27000	5950	2500	2800		
PW30.0	30000	6560	2500	2800		
PW32.0	32000	6970	2500	2800		
PW36.0	36000	7784	2500	2800		
PW40.0	40000	8598	2500	2800		
PW45.0	45000	9616	2500	2800		
PW50.0	50000	10636	2500	2800		
PW54.0	54000	11450	2500	2800		
PW60.0	60000	12765	2500	2800		
PW65.0	65000	13660	2500	2800		
PW70.0	70000	14710	2500	2800		
PW75.0	75000	15730	2500	2800		
PW80.0	80000	16730	2500	2800		
PW84.0	84000	17560	2500	2800		

NOTES.

1. TANK LINER - CRYSTIC 397 - 'WRAS' APPROVED
2. INLET / OUTLET SHOWN IN STANDARD POSITION. CLIENT TO ADVISE ALTERNATIVE ORIENTATIONS, SIZES & INVERTS.
3. INLET / OUTLET FLANGE - BS.4504 PN16 RATING AS STANDARD.
4. NOZZLES COME COMPLETE WITH MILD STEEL/ZINC PLATED SPREADER RING AS STANDARD.
5. 'PW60' AND ABOVE TO HAVE 2 X 600 DIA ACCESS'S. 1250mm IN FROM EACH END OF THE TANK.
6. SHELLS AVAILABLE IN BOTH CLASS 1 (GRANULAR INSTALL) & CLASS 2 (CONCRETE INSTALL).

TANK CODE EXAMPLE -

GRANULAR INSTALL (CLASS 1 SHELL) - PW22.0/1
 CONCRETE INSTALL (CLASS 2 SHELL) - PW22.0/2



TITLE
 'PW' POTABLE WATER RANGE - GENERIC

REV.	DATE	BY	CHKD.	APPD.	DESCRIPTION
5	04/06/15	RP	KB	RP	COMPANY NAME CHANGE
4	28.11.13	KB	PJ	PJ	LINER RESIN CHANGED
3	25.10.07	R.U.	PB	RP	PW4.0 LENGTH AMENDED
2	19.01.07	R.U.	RP	CPG	ISSUED TO SALES DEPT FOR INFO

DRAWN BY R.U.	CHKD. RP	APPD. CPG	SCALE N.T.S.	DRAWING No. PW - GENERIC	REVISION 5
DATE 30/5/02	DATE 30/5/02	DATE 30/5/02			

DO NOT SCALE
 IF IN DOUBT ASK
 ALL DIMENSIONS IN MM

THIS DRAWING IS THE PROPERTY OF
 PREMIER TECH AQUA LIMITED AND IS NOT TO BE
 COPIED IN PART OR WHOLE WITHOUT WRITTEN PERMISSION