



from
Southern Water 

Horsham District Council
Parkside
Chart Way
Horsham
West Sussex
RH12 1RL

Your ref
DC/25/1827

Our ref
DSA000049281

Date
24th of November 2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Demolition of existing buildings and erection of 1No detached self-build dwelling with associated works.

Site: Oremham Manor Farm Oremham Common Henfield West Sussex.

Thank you for your correspondence, please see our comments below regarding the above application.

Proposed soakaways

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development. No new soakaways should be located within 5 metres of a public or adoptable gravity sewer, rising main or water main.


No Soakaways should be connected to the public surface water sewer.

Proposed Disposal to ground from package treatment plant

The Environment Agency should be consulted directly by the applicant regarding the use of a private wastewater treatment works which disposes of effluent to sub-soil irrigation.

Proposed works involve demolition

In order to protect and safeguard the existing water supply apparatus, Southern Water requests formal notification of any proposed demolition works prior to such works being undertaken.



For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development



Controllable Valve	Flow Control	Inlet-Outfall
Damboards Penstock Valve	Anti Flood Device Pumped Anti Flood Device Reflux Valve	Inlet Outfall
BIF Bifurcation Cascade CP Catchpit Head Of Public Sewer IC Interceptor Chamber Manhole S Soakaway WO Washout		
Outfall Headworks	Overflow Chamber	Pipe Bridge
Outfall Headworks CSO Combined Sewer Overflow	EMO Emergency Overflow	Pipe Bridge Micro Pumping Station Pumping Station
Sewer Level Monitor	Storage	Treatment Works
Sewer Level Monitor Storm Tank Tidal Storage Tank		Treatment Works Weir Wastewater Site
Wastewater Pipe	Wastewater Use	Developer Services
Culverted Water Course Drain Outfall Overflow Rising Main Sewer	Syphon Tank Sewer Trunk Sewer Vacuum Main Decommissioned Pipe	Foul Combined Sludge Treated Effluent Surface Water Private
		Build Over Agreement Section 104
Wastewater Area		
		Catchment Sub-Catchment

Map Title: DSA000049281 GIS

Printed By: Kelly.Donaldson

Date Printed: 24/11/2025

Map Scale: 750

The information provided is believed to be correct but is provided on an 'as is' basis and without any warranty or condition express or implied, statutory or otherwise as to its quality or fitness for purpose. Actual positions of assets should always be determined on site.

