

From: Isabelle.Carter
Sent: 22 September 2025 11:25
To: Nicola.Pettifer
Cc: Planning
Subject: DC/25/1155 - Land East of Tilletts Lane, Warnham (2)

Categories: Consultations

Dear Nicola,

In response to the updated Water Neutrality Statement provided by the applicant, we have the following comments to make:

We acknowledge the revisions made to the Water Neutrality Statement in response to our previous comments. However, we note that a schematic has still not been provided. While the report references Figure B.2 of BS EN 16941-1:2024, this figure was not included, and in any case, it does not constitute a site-specific schematic, so would not be an acceptable submission.

The report mentions the procedure that will be undertaken in the case of system and sample failures. However, there needs to be a plan for a continuity of supply in the instance of continued system/sample failures (not just for periods of drought).

Kind regards,

Isabelle Carter
Scientific Officer (Environmental Protection)



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton