

**From:** Planning@horsham.gov.uk <Planning@horsham.gov.uk>  
**Sent:** 05 September 2025 11:10:47 UTC+01:00  
**To:** "Planning" <planning@horsham.gov.uk>  
**Subject:** Comments for Planning Application DC/25/1312  
**Categories:** Comments Received

## Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 05/09/2025 11:10 AM.

### Application Summary

Address:	Land West of Ifield Charlwood Road Ifield West Sussex
Proposal:	Hybrid planning application (part outline and part full planning application) for a phased, mixed use development comprising: A full element covering enabling infrastructure including the Crawley Western Multi-Modal Corridor (Phase 1, including access from Charlwood Road and crossing points) and access infrastructure to enable servicing and delivery of secondary school site and future development, including access to Rusper Road, supported by associated infrastructure, utilities and works, alongside: An outline element (with all matters reserved) including up to 3,000 residential homes (Class C2 and C3), commercial, business and service (Class E), general industrial (Class B2), storage or distribution (Class B8), hotel (Class C1), community and education facilities (Use Classes F1 and F2), gypsy and traveller pitches (sui generis), public open space with sports pitches, recreation, play and ancillary facilities, landscaping, water abstraction boreholes and associated infrastructure, utilities and works, including pedestrian and cycle routes and enabling demolition. This hybrid planning application is for a phased development intended to be capable of coming forward in distinct and separable phases and/or plots in a severable way. cr
Case Officer:	Jason Hawkes

[Click for further information](#)

### Customer Details

Address: UK Power Networks, Barton Road BURY ST. EDMUNDS

## Comments Details

Commenter Type:	Consultee
Stance:	Customer made comments neither objecting to or supporting the Planning Application

Reasons for comment:

Comments:	<p>We note there are overhead cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.</p> <p>In the instance of overhead cables within the vicinity, All works should be undertaken in line with GS6 guidelines as published by the HSE</p> <p>Should any diversion works be necessary because of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG. You can also find support and application forms on our website Moving electricity supplies or equipment   UK Power Networks</p>
-----------	--

Kind regards

Telephone:

Email: [planning@horsham.gov.uk](mailto:planning@horsham.gov.uk)



Horsham  
District  
Council

**Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB**

Telephone: 01403 215100 (calls may be recorded) [www.horsham.gov.uk](http://www.horsham.gov.uk) Chief Executive: Jane Eaton