

**From:** FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>  
**Sent:** 05 September 2025 08:22:43 UTC+01:00  
**To:** "Planning" <planning@horsham.gov.uk>  
**Subject:** Large Development Hydrant Condition - DC/25/1312 Land West of Ifield  
Charlwood Road Ifield West Sussex  
**Attachments:** LDHC - DC.25.1312 Land West of Ifield, Charlwood Road, Ifield, West  
Sussex.docx  
**Categories:** Consultations

FAO: Jason Hawkes

Dear Jason,

Please find attached a planning condition for application no. DC/5/1312 for the requirement of additional fire hydrant(s) for the proposed development. This is to ensure that all dwellings on the proposed site are within 150 metres of a fire hydrant for the supply of water for firefighting, and all commercial premises are within 90 meters of a fire hydrant.

Evidence will also be required that Fire Service vehicle access meets with the requirements identified in Approved Document B Volume 1 2019 Edition: B5 Section 13, including Table 13.1 and diagram 13.1.

Regards



**Ian Stocks**

Water & Access Manager - Protection

**West Sussex Fire & Rescue Service**

**Office** 0330 222 4499   **Mobile** 07921 291051

**Web** [www.westsussex.gov.uk/fire](http://www.westsussex.gov.uk/fire)

**Email** [frs.waterandaccess@westsussex.gov.uk](mailto:frs.waterandaccess@westsussex.gov.uk)

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his

[Click here to find out why we use pronouns in our signatures](#)



---

#### LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before

opening any attachment.

---