

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 03 September 2025 12:32:46 UTC+01:00
To: "Planning" <planning@horsham.gov.uk>
Subject: Planning consultation - DC/25/0446 Crays Barn Crays Lane Goose Green
Pulborough West Sussex RH20 2LR
Categories: Consultations

FAO: Hannah Darley

Dear Hannah,

Having viewed the details provided for planning application DC/25/0446 for the demolition of 2no. agricultural buildings and the erection of 3no. dwellings; further evidence is required to show Fire Service access complies with Approve Document B (AD-B) Volume 1: B5 section 13. This should include information to show a suitable width for a fire appliance will be provided, a minimum of 3.1m through any gateway or narrowing, 3.7m between roadside kerbs or track edges, capable of supporting 18-Tonne axial weight of a fire appliance and a suitable turning facility provided to ensure a fire appliance can turn and make their exit in a forward direction, as identified in AD-B Volume 1.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his 

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
