



Abnormal or unusual residual risks associated with the design outcomes shown on this drawing are:-

RSK LDE LTD has followed its Design Risk Management process for Hazard Elimination and Risk reduction in developing the designs shown on this drawing.

Abnormal or unusual residual risks may be shown above where it is considered that such risk may not normally be expected by competent persons engaged on work of this nature or type.



Notes:

1. This drawing is to read in conjunction with the Standard Details, the layouts, schedules and specification for this project.
2. All adoptable drainage to be constructed in conjunction with Design and Construction Guidance for Drainage or as stipulated in Southern Water Addendum.
3. For guidance on types and distances of proposed trees away from adoptable sewers refer Design and Construction Guidance for Drainage Restrictions On Tree Planting Adjacent To Sewers.
4. A + 1% gradient represents a rise of 1m in 100m.
5. Left and right hand channels are on the left and right hand side respectively, when standing at zero chainage and looking along the road.
6. A level at any point 'X'm from the start of a vertical curve is given by the formula:-  

$$\text{Level at 'X' = Level @ start of the curve} + \frac{AX}{100} \left( \frac{A-B}{200L} \right) X^2$$
 where A and B are the gradients at the start and end of the curve respectively and having the algebraic signs +/,- , , -
7. LHG and RHG indicates a left and right hand gully respectively.
8. Pipe sizes are stated in millimetres and levels are shown in metres A.O.D.
9. All pipes to have flexible joints with granular bedding (Class S) unless stated otherwise. Where 150mm concrete bed and surround is specified the concrete must be broken at the joint positions by the insertion of a "flexcell" collar.
10. Connections to existing sewers are to be "SOFFIT TO SOFFIT" unless noted otherwise.
11. All concrete pipes to be CLAS M All clay pipes shall comply with BS EN 205-1 crushing strength and shall have a minimum crushing crushing strength of 38kN/m. All Concrete pipes 3000 and above shall be claS 120 and have a minimum crushing strength of 38kN/m
12. 'MV' is equal to the rate of change of gradient and is calculated from the formula:-  

$$MV = 100 \times \frac{(A-B)}{L}$$
 where A and B are as in Note 4 above.
13. Existing levels to be confirmed on site prior to commencement of works.

P04	30.06.25	Long Section updated to suit new site layout	SB	GXA	RD
P03	13.12.2024	Issued for PLANNING RESUBMISSION	SB	GXA	RD
Rev.	Date	Amendment	Drawn	Chkd.	Appd.

<div><div><div><div><div>LDE</div><div>CIVILS</div></div><div><div>STRUCTURES</div><div>an  company</div></div><div><div>HYDROLOGY</div><div></div></div></div><div></div></div></div>													
Abbey Park Hunster Road Coventry CV3 4AQ United Kingdom				Tel: +44 (0) 24 7650 5800 Fax: +44 (0) 24 7650 1417 Email: <a href="mailto:info@rsk.co.uk">info@rsk.co.uk</a> Web: <a href="http://www.rsk.co.uk">www.rsk.co.uk</a>									
Client				BARRATT DAVID WILSON (SOUTHERN COUNTIES)									
Project Title				NEW PLACE FARM PULBOROUGH WEST SUSSEX									
Status				PLANNING									
Drawing Title				LONG SECTION ROADS 10A AND 10B									
Drawn LN		Date 09.24		Checked GXA		Date 09.24		Approved RD		Date 09.24			
Scale 1:500				Orig Size A1				Dimensions m					
Project No. 890815						Drawing File 890815-RSK-ZZ-XX-DR-C-8013 to 8022 Long Sections.dwg							
Drawing No.										Rev.			
890815		RSK		ZZ		XX		DR		C 8019		P04	
Project		Orig.		Vol/Sys.		Lev./Loc.		Type		Role		Draw. No.	
Scale 1:500													
<div><div>0</div><div>5</div><div>10</div><div>15</div><div>20</div><div>25m</div></div>													