

From: Isabelle.Carter
Sent: 23 October 2025 12:14
To: Kate.Turner
Cc: Planning
Subject: DC/25/1371 Land West of Parsons Field Stables Pickhurst Lane Pulborough

Categories: Consultations

Dear Kate,

Our comments on the above application are below:

1. We appreciate the clarity provided on the number of tanks and associated pipework.
2. The guidance referenced in this report needs to be The Private Water Supplies (England) Regulations 2016, rather than The Water Supply (Water Quality) Regulations 2016. Although it has been mentioned in relation to the risk assessment, it must also be the regulations used to determine sampling parameters and frequency.
3. We note the site-specific plan has been removed from the report, but no schematic of the rainwater harvesting system has been provided. Please submit a clear schematic that shows the full system from collection to point of use. The schematic must indicate where each element of treatment will be located within the system and include sufficient detail.

Kind regards,

Isabelle Carter

Scientific Officer (Environmental Protection)

[REDACTED]



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton