

From: Michael isherwood [REDACTED]
Sent: 04 July 2025 09:48
To: Meg.Bayliss [REDACTED]
Subject: Re: FW: DC/25/0040

Hi Meg,

Sorry I was out all day yesterday.

Please find attached which shows the following:

- Green Circle - 45m radius directly from the hydrant on opposite side of the road (with hose route through proposed clearing).
- Orange Circle - 45m radius from the layby with existing pedestrian access (on basis fire engine with on board supply/pump appliance can park here)
- Blue Circle - 45m radius directly opposite dwelling on road, at entrance of the proposed clearing (on basis fire engine with on board supply/pump appliance can park here)

Hopefully this is clear and sufficient.

Happy to agree to slight extension into next week to give you time to confirm this and get sign off of the report.

Have a good weekend and I'm sure we will be in touch next week.

Regards,
Michael