

Ground Floor
Northleigh
County Hall
Chichester
West Sussex
PO19 1RH



Lead Local Flood Authority

Sam Whitehouse
Development Control
Horsham District Council
Albery House
Springfield Road
Horsham
RH12 2GB

Date 19/12/2025

Dear Sam,

RE: DC/25/1922 - Land West of Bines Road Bines Road Partridge Green RH13 8EQ

Thank you for your consultation on the above site, received on 02nd December 2025. We have reviewed the application as submitted and wish to make the following comments.

Following a review of the documents submitted, we have **no objection** to this application, subject to the following conditions:

Condition 1

Prior to the commencement of development, construction drawings of the surface water drainage network, associated sustainable drainage components and flow control mechanisms and a construction method statement shall be submitted and agreed in writing by the Local Planning Authority. The scheme shall then be constructed as per the agreed drawings, method statement, FRA (06/11/2025 Rev D with appendices) and remain in perpetuity for the lifetime of the development unless agreed in writing by the Local Planning Authority. No alteration to the agreed drainage scheme shall occur without prior written approval from the Local Planning Authority.

Reason: To ensure that the development achieves a high standard of sustainability and to comply with NPPF and Local Planning Policy 38.

Condition 2

The development hereby approved shall not be first occupied until details of the maintenance and management of the sustainable drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the

sustainable drainage scheme for the lifetime of the development. The details of the scheme to be submitted for approval shall include:

- I. a timetable for its implementation,
- II. details of SuDS features and connecting drainage structures and maintenance requirement for each aspect
- III. a management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Policy 38

Condition 3

Upon completion of the surface water drainage system, including any SuDS features, and prior to the first occupation of the development; a survey and report from an independent surveyor shall be submitted to and approved in writing by the Local Planning Authority. The survey and report shall demonstrate that the surface water drainage system has been constructed in accordance with the details approved pursuant to condition 1. Where necessary, details of corrective works to be carried out along with a timetable for their completion, shall be included for approval in writing by the Local Planning Authority. Any corrective works required shall be carried out in accordance with the approved timetable and subsequently re-surveyed with the findings submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the flood risk is adequately addressed, not increased and users remain safe for the lifetime of the development in accordance with NPPF and Policy 38.

Yours sincerely,

Natalie Biddulph
Flood Risk Management Team
FRM@westsussex.gov.uk

Annex:

The following documents have been reviewed:

- Motion Flood Risk Assessment and Drainage Strategy 06/11/2025 Rev D with appendices