

[REDACTED]

From: Susan.Lee
Sent: 11 March 2026 10:56
To: Bethan.Tinning
Cc: [REDACTED]
Subject: DC/26/0166

Categories: Consultations

Application No: DC/26/0166

Address: Fox Inn Guildford Road Bucks Green

Proposal: Erection of a single storey side extension, and internal and external alterations. (Full Application).

Case Officer: Bethan Tinning

I have examined the above planning application and advise that I have no objections to the proposal.

The applicant should be mindful that the new bar area should be serviced with a wash hand basin, to enable the bar staff to wash their hands, and a separate sink for equipment washing and disposing of dregs etc.

The applicant should also ensure that the siting of the compressor unit for the new cellar is such that it does not cause a nuisance to nearby neighbours.

Kind regards,

Susan Lee

Area Environmental Health Officer

Telephone: 01403 215428

Email: Susan.Lee@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton