

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 13 January 2026 15:58:57 UTC+00:00
To: "Planning" <Planning@southdowns.gov.uk>
Subject: Planning consultation - DC/25/2121 Old House Manor Estate Cowfold Road
Coolham West Sussex RH13 8QL

Caution: This email originates from outside of South Downs National Park Authority and could contain malicious content. Please think very carefully before opening attachments or clicking on links.

FAO: Alice Johnson

Dear Alice,

Having viewed the plans for the planning application no. DC/25/2121 for the conversion of existing manor house into 14no. residential units. (Retrospective); evidence is required to show that all points inside all flats are within 45 metres of the location of a fire appliance in accordance with Approved Document B (AD-B) Volume 1 B5 section 13. This is to be measured along the hose lay route, not in a direct line or arc measurement as this type of measurement can rarely be achieved due to obstructions. Any areas not within the 45-metre distance will need to be mitigated by the installation of sprinkler or water mist system complying with BS9251 or BS8458 standards.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his 🏳️‍🌈

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If

it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
