



## HORSHAM DISTRICT COUNCIL CONSULTATION

<b>TO:</b>	Development Control
<b>FROM:</b>	Environmental Health and Licensing
<b>REFERENCE</b>	DC/25/1439
<b>LOCATION:</b>	Lower Perryland Farm, Basing Hill Access Road, Dial Post, West Sussex, RH13 8NT
<b>DESCRIPTION:</b>	Demolition of existing agricultural barns and erection of 3no. residential dwellings, with associated car ports, landscaping and parking.
<b>RECOMMENDATION:</b>	No objection subject to conditions

### MAIN COMMENTS:

#### Land Contamination

1. Environmental Health have reviewed the revised Onyx Geo Consulting Ltd Phase 1 Report, submitted in support of the application, and we are now satisfied with the preliminary assessment of the risk to future site users.
2. We agree with the recommendations in the report in that to confirm ground condition on the site and to fully quantify the risks to future site users ground investigations should be undertaken on the site.
3. We are happy to request this through conditions and we therefore recommend the below conditions, given the need for these investigations to be undertaken post demolition but pre-construction of the dwellings this condition has therefore been worded accordingly.
4. Given our comments on the site investigations to satisfy conditions for a previous scheme we ask however that before the commencement of any further ground investigation works that the applicants environmental consultant contact Environmental Health so that the scope of the additional investigations can be formally agreed.

#### Construction Phase

During site clearance, preparation and construction there is the potential for local residents to experience adverse impacts from noise, dust and construction traffic movements. These should be minimised and controlled by the developer and a construction environmental management (CEMP) plan is recommended as a condition.

**ANY RECOMMENDED CONDITIONS:****Land Contamination**

**The construction of the dwellings hereby approved shall not commence until the following components of a scheme to deal with the risks associated with contamination, (including asbestos contamination), of the site has been submitted to and approved, in writing, by the local planning authority:**

- (a) An intrusive site investigation scheme to provide information for a detailed risk assessment to the degree and nature of the risk posed by any contamination to all receptors that may be affected, including those off site.**
- (b) Full details of the remediation measures required and how they are to be undertaken based on the results of the intrusive site investigation (a) and a verification plan providing details of what data will be collected in order to demonstrate that the remedial works are complete.**

**The scheme shall be implemented as approved. Any changes to these components require the consent of the local planning authority.**

**Reason:** As this matter is fundamental to ensure that no unacceptable risks are caused to humans, controlled waters or the wider environment during and following the development works and to ensure that any pollution is dealt with in accordance with Policies 24 and 33 of the Horsham District Planning Framework (2015).

And

**The development hereby permitted shall not be occupied/brought into use until there has been submitted to the Local Planning Authority verification that the remediation scheme required and approved under the provisions of condition X(b) has been implemented fully in accordance with the approved details (unless varied with the written agreement of the Local Planning Authority in advance of implementation). Thereafter the scheme shall be monitored and maintained in accordance with the scheme approved under condition X(b), unless otherwise agreed in writing by the Local Planning Authority.**

**Reason:** As this matter is fundamental to ensure that no unacceptable risks are caused to humans, controlled waters or the wider environment during and following the development works and to ensure that any pollution is dealt with in accordance with Policies 24 and 33 of the Horsham District Planning Framework (2015).

**Construction Phase**

**The development hereby approved shall not commence until a Construction and Environmental Management Plan (CEMP) has been submitted to and approved in writing by the local planning authority. The CEMP shall include details of the following relevant measures:**

- i. An introduction consisting of construction phase environmental management plan, definitions and abbreviations and project description and location;**
- ii. A description of management responsibilities;**
- iii. A description of the construction programme which identifies activities likely to cause high levels of noise or dust;**
- iv. Site working hours and a named person for residents to contact;**
- v. Detailed Site logistics arrangements;**
- vi. Details regarding parking, deliveries, and storage;**

- vii. Details regarding dust and noise mitigation measures to be deployed including identification of sensitive receptors and ongoing monitoring;
- viii. Details of the hours of works and other measures to mitigate the impact of construction on the amenity of the area and safety of the highway network; and
- ix. Communication procedures with the LBL and local community regarding key construction issues – newsletters, fliers etc.
- x. Details of traffic construction routing to and from the site

The construction shall thereafter be carried out in accordance with the details and measures approved in the CEMP for the related phase.

**Reason:** As this matter is fundamental in order to consider the potential impacts on the amenity of nearby occupiers during construction and in accordance with Policy 33 of the Horsham District Planning Framework (2015).

<b>NAME:</b>	Kevin Beer
<b>DEPARTMENT:</b>	Environmental Health and Licensing
<b>DATE:</b>	25/11/25