From: assistant clerk <assistant.clerk@rudgwick-pc.gov.uk>
Sent: 21 November 2024 11:25:21 UTC+00:00
To: "Planning" <planning@horsham.gov.uk>
Cc: "Anna Clayton" <clerk@rudgwick-pc.gov.uk>; "assistant clerk" <assistant.clerk@rudgwick-pc.gov.uk>
Subject: DISC/24/0280 The Stables
Categories: Consultations

Good morning

Please find Rudgwick Parish Councils observations below:

Delegated Applications for noting at Rudgwick Parish Council Meeting 9th December 2024	
Application No: DISC/24/0280 05.11.2024	**Response:** RPC do not feel as if they have sufficient knowledge to comment on the technical aspects of the details provided, and whether they meet the requirements for discharge. However, it has been noted that HDC drainage team stated in response to DC/24/0103 that flow control chambers must be provided with an overflow weir, and RPC see no weir.
Applicant: The Stables, Loxwood Road, Rudgwick	
Reason for Application: Approval of details reserved by condition 4 and 5 to approved application DC/24/0103.	
Official Response Date: 28.11.2024 (determination 31.12.2024)	

With kind regards
Sarah

Sarah Hall
Assistant Clerk to Rudgwick Parish Council

Tel nr: 01403 822678
Working hours: Monday, Thursday and Friday 8.00 – 16.00
E-mail: assistant.clerk@rudgwick-pc.gov.uk