[redacted]

From: Lee.Money
Sent: 08 March 2024 09:53
To: Shazia Penne
Cc: Planning
Subject: RE: DISC/23/0237 Pentland New Hall Lane Small Dole Henfield EH response

Categories: Consultations

Hi Shazia

The only comment with respect to this application relates to the discharge of condition 8 of approved application DC/21/1523 relating to the proposed supply of rainwater to supply the WC's and washing machine.
The DWI technical guidance states that the water for domestic purposes needs to treated to ensure it is of appropriate quality and this includes water used for laundry purposes.

Please can you ask the applicant to confirm that the water supplied to the washing machine will be treated in accordance with the DWI technical guidance requirements.

Thanks

[redacted]

Lee Money
Team Leader Environmental Protection
[redacted]
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
-----Original Message-----
From: planning@horsham.gov.uk <planning@horsham.gov.uk>
Sent: 28 February 2024 09:39
To: [redacted]
Subject: Planning Application Consultation - DISC/23/0237

Please see the attached consultation letter from Horsham District Council Re:DISC/23/0237