From: Lee.Money
Sent: 21 March 2024 10:59
To: Jacques.Burrowes
Subject: RE: Planning Application Consultation - DC/24/0171 103 Rushams Road Horsham EH response

Hi Jacques

Thanks for loading the document. Unfortunately they appear have cropped the columns and left off the actual noise levels.

I have had a look on the Daiken website and this gives a noise level for that unit of 50dBA at 1m

The problem with units sited above ground floor level is the noise is less screened by fences etc. Also the nose from this type of equipment is highly directional and I note the unit will be facing towards the adjoining house.

I would recommend the unit is sited at ground level and relocated to point away from neighbouring occupiers. If this is not possible the application should be conditioned to ensure the unit runs in low power mode only between 23:00 and 07:00 hours.

lee

Lee Money
Team Leader Environmental Protection
Telephone: 01403 215410 |
07879481032
Email:Lee.Money@horsham.gov.uk
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
-----Original Message-----
From: Jacques.Burrowes <Jacques.Burrowes@horsham.gov.uk>
Sent: 21 March 2024 09:30
To: Lee.Money <Lee.Money@horsham.gov.uk>
Subject: RE: Planning Application Consultation - DC/24/0171 103 Rushams Road Horsham

Hi Lee

I've upload the specs to Info@Work under 'UNIT SPECS [.XLS]'. Let me know if you can assess with these or you need additional. I am considering asking the agent whether the unit can be positioned on the floor to attenuate sound.

Best

Jacques Burrowes
Planning Technician
Telephone: 01403 215180
Email:Jacques.Burrowes@horsham.gov.uk
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
-----Original Message-----
From: Lee.Money <Lee.Money@horsham.gov.uk>

Sent: 16 February 2024 12:43
To: Jacques.Burrowes <Jacques.Burrowes@horsham.gov.uk>
Subject: RE: Planning Application Consultation - DC/24/0171 103 Rushams Road Horsham

Hi Jacques

Please can you ask the applicant for manufacturer's specifications details of the air conditioning unit to be installed. I need the noise data to assess potential for impacts on amenity.

Thanks

lee

Lee Money
Team Leader Environmental Protection
Telephone: 01403 215410 |
07879481032
Email:Lee.Money@horsham.gov.uk
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
-----Original Message-----
From: planning@horsham.gov.uk <planning@horsham.gov.uk>
Sent: 16 February 2024 10:36
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>
Subject: Planning Application Consultation - DC/24/0171

Please see the attached consultation letter from Horsham District Council Re:DC/24/0171