Horsham District Council

Stessie Aristide
UK Power Networks PLC
Property & Consents
C/O Energy House
Hazelwick Avenue
Three Bridges
Crawley
RH10 1EX

Our ref:	DC/24/0297
Your ref:	8500238418
Email:	planning@horsham.gov.uk
Direct Line:	01403 215633
If Calling Please ask for:	Guy Everest
Date:	19th March 2024

Dear Sir/Madam,

To dismantle and replace 4 spans of low voltage overhead lines between poles 562798 and 551763. To decommission and remove the existing 25 KVA pole mounted transformer (pmt) off of pole 562798 and replace with a new 50KVA pmt. To install a new stay wire on pole 562798. To install new LV earth cable as shown on the plan. To install a new stay wire on pole 551761. To install 2 new stay wires on pole 551763. To install a new underground service cable to Highcroft Farmhouse

Highcroft Farmhouse Gay Street Pulborough West Sussex

I refer to your application received in this office on 6th February 2024 concerning the above site.

This Authority does not have any objection to the above works and they may proceed under the terms of the Overhead Line (Exemption) (England and Wales) Regulations 2009.

Yours faithfully

Emma Parkes
Head of Development and Building Control