

From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 21 January 2026 11:38:17 UTC+00:00
To: "Halima.Chowdhury" <Halima.Chowdhury@horsham.gov.uk>
Subject: RE: DISC/26/0010 Roffey Football Club Bartholomew Way EH response

Hi Halima

Thanks for the consultation request.

The lighting details are satisfactory but I would request clarification on the pits detailed below:

Use of visors

Are visors to be fitted to the luminaires ? If so are these included in the lighting assessment?
Angle of Luminaires

Angle setting of Luminaires

Angle of luminaires is important. Complaints were previously received regarding the use of the floodlighting principally caused by the angle that the luminaires were set to. For the lights sited on the north eastern side of the sports pitch the luminaires should kept horizontal with no upward inclination.

Please can you ask the applicant to confirm these details.

Regards

Lee Money

Team Leader Pollution

Telephone: 01403 215410 | 07879 481032

Email: Lee.Money@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

From: Planning <planning@horsham.gov.uk>
Sent: 15 January 2026 09:30
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>
Subject: Planning Application Consultation - DISC/26/0010

Please see the attached consultation letter from Horsham District Council
Re:DISC/26/0010

Telephone:

Email: planning@horsham.gov.uk



Horsham District Council, Alberty House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton