From: Lee.Money [redacted]
Sent: 20 September 2024 15:44
To: Jacques.Burrowes [redacted]
Subject: RE: Planning Application Consultation - DC/24/1315 EH response

Hi Jacques

Thanks for the consultation request.

The proposed location of the air conditioning unit is at a low level and is well screened by the existing fence. I would not expect there to any significant adverse noise impacts arising from the operation of the unit sited at the location shown in the application.

Regards

Lee

Lee Money
Team Leader Environmental Protection
[redacted]
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
-----Original Message-----
From: Planning <planning@horsham.gov.uk>
Sent: 19 September 2024 14:07
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; [redacted]
Subject: Planning Application Consultation - DC/24/1315

Please see the attached consultation letter from Horsham District Council Re:DC/24/1315