
From: FRS Water and Access [REDACTED]
Sent: 13 April 2026 16:17
To: Planning
Subject: Hydrant condition - DC/25/1531 Haynes Littleworth Lane Partridge Green West Sussex RH13 8JF
Attachments: HC - DC.25.1531 Haynes, Littleworth Lane, Partridge Green, RH13 8JF.docx
Categories: Consultations

FAO: Hannah Darley

Dear Hannah,

Please find attached a planning condition for application no. DC/25/1531 for the requirement of an additional fire hydrant. Currently the nearest Hydrant to these proposed properties is 250 metres away. The supply of water for firefighting for a domestic premises should be within 175 metres. If an alternative supply of water for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service. For open water such as ponds, lakes, and rivers etc. evidence will be required to show the habitat in and around the proposed water supply does not have protected species living in them, in accordance with Natural England guidance.

Evidence is also required to show suitable access and turning facility for a fire appliance to attend the dwelling to ensure they comply with the requirements of AD-B Volume 12: B5 section 13. The plan submitted the turning area will be gravel; this will need to be capable of supporting 18-Tonne axial weight of a fire appliance. The access route will need to be 3.1-metres wide through any gateway or narrowing, 3.7 metres between curbs or track edge road

Regards
Ian

Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 [REDACTED]

Web www.westsussex.gov.uk/fire

Email frswaterandaccess@westsussex.gov.uk

Bognor Regis Fire Station, West Meads Drive, West Sussex, PO21 5TB

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to

ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

WEST SUSSEX COUNTY COUNCIL
WEST SUSSEX FIRE AND RESCUE SERVICE

HYDRANT CONDITION CONSULTATION WITH PLANNING AUTHORITY

Date: 13.04.2026

To: Hannah Darley

From: Ian Stocks

Planning Ref: DC/25/1531

Address: Haynes Littleworth Lane Partridge Green West Sussex RH13 8JF

Description: Erection of detached two-storey dwelling and creation of new vehicle access and driveway from Littleworth Lane

Date of visit: N/A

RECOMMENDATION

Advice:

☒

Modification:

☐

More Information:

☐

Objection:

☐

No Objection:

☐

Refusal:

☐

Total number of hydrants required

| One

This application has been dealt with in accordance with the statutory obligation placed upon Fire and Rescue Service by the following act;

***Fire and Rescue Services Act 2004
Part 5, 38: Duty to secure water supply etc.***

- 1) A fire and rescue authority must take all reasonable measures for securing that an adequate supply of water will be available for the authority's use in the event of fire.*

This proposal has been considered by means of desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC mapping and Fire and Rescue Service information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments:

1) Prior to the commencement of the erection of the new dwelling, details showing the proposed location of the required fire hydrant or stored water supply (in accordance with the West Sussex Fire and Rescue Guidance Notes) shall be submitted to and approved in writing by the Local Planning Authority in consultation with West Sussex County Council's Fire and Rescue Service. These approvals shall not be unreasonably withheld or delayed.

2) Prior to the first occupation of the new dwelling, they will at their own expense install the required fire hydrant in the approved location to BS 750 standards or stored water supply and arrange for their connection to a water supply which is appropriate in terms of both pressure and volume for the purposes of firefighting.

3) Prior to the first occupation of the new dwelling, they will notify West Sussex County Council's Fire and Rescue Service that the fire hydrant has been installed, operational, and ready for use to ensure that the Fire and Rescue Service are aware that the hydrant(s) is now a usable asset in the event of a fire.

The fire hydrant shall thereafter be maintained as part of the development by the water undertaker at the expense of the Fire and Rescue Service if adopted as part of the public mains supply (Fire Services Act 2004) or by the owner / occupier if the installation is retained as a private network.

As part of the Building Regulations 2004, adequate access for firefighting vehicles and equipment from the public highway must be available and may require additional work on or off site, particularly in very large developments. (BS9999 2017 - section 21) for further information please contact the Fire and Rescue Service.

If a requirement for additional water supply is identified by the Fire and Rescue Service and is subsequently not supplied, there is an increased risk for the Service to control a potential fire. It is therefore recommended that the hydrant condition is implemented.

Reason: In the interests of amenity and in accordance with policy CP13 of the Horsham District Local Development Framework; Core Strategy and DC40 of the Horsham District Local Development Framework: General Development Control Policies (2007) and policy CP3 of the Horsham District Local Development Framework Core Strategy (2007), HDPF Policies 33 and 39 and in accordance with The Fire & Rescue Service Act 2004

Ian Stocks

Water and Access Manager

Email: frs.waterandaccess@westsussex.gov.uk