HORSHAM DISTRICT COUNCIL CONSULTATION

TO:	Horsham District Council – Planning Dept
LOCATION:	Tesco Express Redkiln Way Horsham West Sussex
DESCRIPTION:	Replacement of existing fuel tanks, fills, pipework and forecourt with alterations to existing parking arrangements.
REFERENCE:	DC/25/0029
RECOMMENDATION:	Advice

MAIN COMMENTS:

The installation has a permit **PSS01** issued under Regulation 13 of the Environmental Permitting (England and Wales) Regulations 2016 to operate an installation carrying out Section 1.2 B (c) and Section 1.2 B (d) activities listed in Part 2 to Schedule 1 of those Regulations, to the extent authorised by the Permit.

Should the proposed development be approved, a Part B application for a Variation of the Permit should be sent to the Regulator and must contain a description of the proposed change in the nature or functioning, or an extension, of the installation, which may have consequences for the environment. There is no applicable fee for this variation application.

Please note that Petrol delivery and vapour recovery systems for vehicle petrol tanks should be tested in accordance with the manufacturer's specifications prior to commissioning and for Vapour containment integrity following substantial changes.

NAME:	Thais Delboni
DEPARTMENT:	Environmental Health
DATE:	12 February 2025