

Hi Sophie,

Lee sent this to me to have a look at the dust section of the CMP and asked to send my comments to you. Please see below.

In Appendix 5 of the Logika Air Quality Assessment (DC/25/0415), dated 13 January 2025, it was said that a Dust Management Plan should be written to include the 'highly recommended' and 'desirable' mitigation measures that were listed in Table A5-1. From reading the CMP, there is very little detail on the mitigation of dust during construction and many of the measures mentioned in the AQA are not mentioned in the CMP. Dust suppression and mitigation shall be in line with the IAQM Guidance on the assessment of dust from demolition and construction (2024), which was also the same as the measures included within the Logika AQA.

There has been no mention of sensitive receptors around the site, or real-time PM10 continuous monitoring. This is important as it is a major site being built in phases, where additional new sensitive receptors will be made during the construction phase.

There should be consideration made to long periods of dry weather, as some measures are reliant on using water to suppress the dust.

The PMP is mentioned in the CMP, but it is not possible to view it in the appendix as it seems to be just an image rather than the file.

Kind regards,

Isabelle Carter

Scientific Officer (Environmental Protection)

Telephone: |

Email:



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex

RH12 2GB

Telephone: 01403 215100 (calls may be recorded)

www.horsham.gov.uk Chief Executive: Jane Eaton



Get on top of the renting changes

New rights and responsibilities for landlords in England.

[Click here to learn more...](#)