Title: (NTR) Millsfield Farm Rusper RH12 4PU

JOB NO: UKPN 8500319741-1-500

PROPOSAL PLOT

*** PLEASE NOTE ***
If the project involves open, un-ducted trenches that have been dug by you or your appointed contractor, UK Power Networks appointed contractor will be responsible for sanding / blinding the trenches and supplying and installing the Tile Tape. You will then be responsible for the final backfill and reinstatement.

If installing ducts you may be asked to provide photographic evidence / proof of the correct duct, depth and install method. You are also responsible for ensuring that ducted routes have been recorded.

All cables discovered must be considered LIVE and DANGEROUS at all times and must not be cut, re-sited, suspended or generally interfered with, unless specifically authorised on-site by an UK Power Networks Engineer. All the cables are UK Power Networks' property and remain so even when made dead, unless we notify you otherwise and any such cable exposed should be reported to the UK Power Networks Engineer for your Development.

1 x LV mains branch joint
185H / 95H
LV Type 2

1 x 95H LV mains pot end and earth
LV Type 2

Install 1 x 185H LV mains pole termination.
2 x cores to be stubbed (Single phase OH).

- LV Overhead span from LV Pole 637408 to 637409 shall be removed.

- LV Pole 637409 shall be removed.

- Associated LV staywire shall be removed.

Site Boundary

- LV Pole 637408 shall be removed

- Install 1 x new LV Terminal Pole

- Install 2 x LV Staywires to new LV Pole

- Reconnect existing 2w 95ABC to new LV Pole

*** PLEASE NOTE ***
The position of the new LV pole and staywires will need to avoid the large oak tree / associated roots and the entrance to the public footpath.

*** PLEASE NOTE ***
The HV overhead network located within the customers site boundary has been quoted to be diverted under UKPN 8500299150.

ALS Responsibilities

1. Complete all offsite excavation and reinstatement of groundworks.
2. Complete all associated traffic management.
3. Install cable within customer site boundary.

Customer Responsibilities:

1. To carry out all excavation and reinstatement of groundworks within the site boundary.

2. The 185H LV mains cable shall be installed in a trench that is a minimum of 450mm deep in the footway and 600mm deep in the carriageway. If the cable is installed within the carriageway, it must be additionally protected by 125mm black solid rigiduct (Smooth inner and corrugated outer embossed ELECTRICITY CABLE DUCT). Refer to ECS 02-0019 for more information.

3. All cables/ducts must be installed with tile tape marked UK POWER NETWORKS.

EAST STREET
511966 (M)

EAST STREET
ABSD
515034

HIGH STREET
ASL'S
505485

Track

Oaks Cottage

Gate Cottage

Thatched Barn Cottage

Acorn Cottage

Red

95scs
95H
125 pvc
TBS
Ass Pos
2c 35H (L2) NR
95H NR (AB)
125 pvc
NR
637409
2w 95ABC
185H
2x125 pvc
618806
637408
616807
2c 35H NR
644984
2w 50ABC
637407
637406
2c 35H
2c 35H NR
2c 35H (L1) NR

Description	Existing	Proposed
LV Cable or Line		
HV Cable or Line		
EHV Cable or Line Approx. position		
Ductline	[ ]	[ ]
Pole & Street Furniture		
Substation & Link Box		

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all cables have been determined.
4. It must be assumed that each property and item of street furniture has an electricity supply. Service cables shown only where known.
5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
6. The information provided must be given to all people working near UK Power Networks plant & equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
2. UK Power Networks does not exclude or limit its liability if it causes the death of any person or causes personal injury to a person where such death or personal injury is caused by its negligence.
3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever.
4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and you must return it to the sender of the letter.
5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

0m 10m 20m 30m 40m 50m 60m 70m 80m

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.

VISITING AN OPEN POINT? Please mark on this plan all locations visited and open points as found, then return updated map to your Business Unit - Thank You.

Contact UK Power Networks on 0800 056 5866 for details of EHV Cable routes before commencing work.

Plan Provision

CHECK IT OUT BEFORE YOU DIG IT OUT
CALL 0800 056 5866
EMERGENCY- If you damage a cable or line Phone 0800 096 3766 (24hrs) URGENTLY

LOOK OUT LOOK UP

ALWAYS LOOK UP BEFORE YOU START WORK
Refer to HSE Guidance note GS6

Maps produced at 1:2500 scale are LV Geo-Schematics which show LV mains cables and overhead lines (in some cases all voltages). Prior to carrying out excavations you must refer to the 1:500 records to determine the location of all known underground plant and equipment.

Grid Ref: TQ 20856 37212

Scale: 1:500
(When Plotted at A2)

Plotted on: 23/12/2024

Plotted by: Matthew Walbank

N W E S

UK Power Networks

Reproduced by permission of Ordnance Survey on behalf of HMSO. (c) Crown copyright and database right 2024. All rights reserved. Ordnance Survey Licence number AC0000850810. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of (c) South Eastern Power Networks plc or London Power Networks plc each being a distribution licensee under section 6(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.