From: Kevin.Beer <Kevin.Beer@horsham.gov.uk>
Sent: 09 April 2025 13:22:57 UTC+01:00
To: "Kate.Turner" <Kate.Turner@horsham.gov.uk>
Subject: DISC/24/0255 - Limekiln Farm

Dear Kate,

Apologies for the delay in providing further comments.

Environmental Health have now reviewed the latest information and we have the following comments to make:

Condition 10 – similar to previous comments the information provided is all rather piecemeal and it is not clear in what order the proposed treatment will be installed. As detailed in previous comments information to satisfy this condition needs to take the form of commentary in one document/technical note along with, ideally, a schematic which clearly shows the order of the proposed treatment system.

Condition 11 – as you will be aware this condition requires the submission of a Private Water Supply Management Plan with sufficient detail on the proposed sampling and testing regime, detail on servicing and maintenance etc. Again this management plan should take the form of one document. Unfortunately I can see no information that would constitute a management plan in the recent submission.

Given the above unfortunately EH are still not in a position where we can recommend the condition 10 and 11 for discharge. I would be happy to meet with the applicant to discuss how they overcome this.

Kind regards

Kevin

Kevin Beer

Environmental Protection Officer (Pollution)

Telephone: 01403 215420
Email: Kevin.Beer@horsham.gov.uk

Horsham District Council