



Alice Johnson
Development Control
Albery House
Springfield Road
Horsham
RH12 2GB

Roads & Sewers for Planning &
Design Ltd
The Business Terrace
Maidstone House
King Street
Maidstone
Kent
ME15 6JQ

Email: Luke.shaw@roadsandsewers.co.uk
Telephone: 01622 910125
Ask for: Luke Shaw
Job No: **6126**
Date: 26th November 2025

Dear Alice,

RE: Danefold House, Littleworth Lane, Partridge Green, RH13 8NA (DC/25/1023)

Following receipt of the planning response from West Sussex County Council, dated 11th November 2025, RSPD have prepared the following detailed response to address the matters raised.

An overlay of the Environment Agency's lidar mapped surface water overland flow routes has been produced, illustrating the extent of interaction with the proposed slurry pit. This can be reviewed on RSPD Drawing 6126-02 Overland Flow Routes.

A plan has been prepared showing the existing surface water overland flow path, along with our assessment of how flows are expected to reroute following the construction of the new slurry pit.

While a portion of the current surface water overland flow will be intercepted by the slurry pit this will be very minor, even in the 1 in 100 year event. Therefore, the proposals are helping to reduce potential flood risk elsewhere, with any remaining overland flow continuing to move southwards, reconnecting with the established surface water route further south.

In summary, the addition of the slurry pit is anticipated to reduce flood risk within the surrounding areas, as less overland surface water will flow across the site and will instead be captured and managed by the proposed slurry pit.



Should you require further information or have any questions relating to this, please don't hesitate to contact me.

Yours Sincerely,

Luke Shaw AMIHE

Civil Engineer

Roads & Sewers for Planning & Design