From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 19 September 2024 10:27:32 UTC+01:00
To: "Jacques.Burrowes" <Jacques.Burrowes@horsham.gov.uk>
Subject: FW: DISC-24-0178 Stables at Glebe Meadow Church Lane Ashurst Steyning

Hi Jacques

I responded to this consultation on 2nd August. See below

Lee

Lee Money
Team Leader Environmental Protection
Telephone: 01403 215410 |
07879 481032
Email:Lee.Money@horsham.gov.uk
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
-----Original Message-----
From: Lee.Money
Sent: 02 August 2024 15:39
To: Kate.Turner <Kate.Turner@horsham.gov.uk>
Cc: Penny.Marsh <Penny.Marsh@horsham.gov.uk>
Subject: RE: DISC-24-0178 Stables at Glebe Meadow Church Lane Ashurst Steyning

Hi Kate

The information provided in respect of condition 4 (drainage) is satisfactory. However the proposed sewage treatment plant is to discharge to a water course. The applicant should provide written conformation the Environment Agency are satisfied that this is acceptable and the system complies with the General Binding Rules for discharge to a surface water.

For Condition 6 (rainwater harvesting) the detail provided are also satisfactory. However occupation should not be permitted until the regulation 6 assessment and sampling of the treated water is provided to the LPA as set out in section 2.3.3 of the Rainwater Harvesting and Purification System Specification document.

Regards

Lee

Lee Money
Team Leader Environmental Protection
Telephone: 01403 215410 |
07879 481032
Email:Lee.Money@horsham.gov.uk
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton
-----Original Message-----
From: Planning <planning@horsham.gov.uk>
Sent: 01 August 2024 16:35
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>

Subject: Planning Application Consultation - DISC/24/0178

Please see the attached consultation letter from Horsham District Council Re:DISC/24/0178