[redacted]

[redacted]

Sent: 17 September 2025 11:04
To: Planning
Subject: Planning Consultation - DC/25/0505 Wiltshire's Farm Pickhurst Lane Pulborough West Sussex RH20 1DA

Categories: Consultations

FAO: Sam Whitehouse

Dear Sam,

Having viewed the plans for the planning application no. DC/25/0505 for the Conversion and extension of buildings to form a single dwelling: the nearest fire hydrant for the supply of water for firefighting is 260-metres away, 85-metres further than the 175-metre distance required for a domestic premises. If an alternative water supply for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service.

Evidence will also be required to show the Fire Service vehicle access meets with the requirements identified in AD-B Volume 1: B5 Section 13, A fire appliance requires a minimum width of 3.1m through any gateway or narrowing and 3.7m between road edge or curbs, and the fire appliance is within 45-metres of all points within each property. A fire appliance should not need to revers more than 20m to reach either a turning facility or an exit point from the site.

Although this is a change of use and extension of an existing property, it is a significant change with increased risk to life and property with no supply of water for firefighting available within the required distance, information the owner may not be aware of, and information that could affect their insurance premiums if water for firefighting is not provided.

Regards

[redacted]
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 **Mobile** [redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to

anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
