

[REDACTED]

From: Amy.Furness
Sent: 21 April 2026 11:03
To: Daniel.Holmes
Cc: Planning
Subject: RE: Planning Application Consultation - DC/26/0454

Categories: Consultations

Good Morning,

HDC Drainage note that no drainage information has been submitted as part of this application.

HDC Drainage request More Information to support this application:

- The applicant should provide evidence of BRE365 Infiltration testing at the location and depth of the proposed SuDS.
- The applicant must provide evidence of measures to prevent pollution of groundwater.
- Maintenance and Management Plans must be provided.

Kind regards,

Amy Furness
Drainage Officer

[REDACTED] | [REDACTED]
[REDACTED] [REDACTED]



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

From: Planning <planning@horsham.gov.uk>
Sent: 31 March 2026 11:36
To: Drainage <Drainage@horsham.gov.uk>; Amy.Furness [REDACTED]
Subject: Planning Application Consultation - DC/26/0454

Please see the attached consultation letter from Horsham District Council Re:DC/26/0454

Telephone:
Email: planning@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton