

Good afternoon Sam,

I am happy for the condition 6 complies / accordance with the condition, just need to ensure there is suitable access to all parts of the new build school. The school will also need to ensure the nearest fire hydrant is within 90-metres of the intended location of the Fire Appliance, as identified in Approved Document – B (AD-B) Volume2: B5 section 16 and BB100: Design for fire safety in schools.

Regards

Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** [REDACTED]

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West
Sussex, PO19 1BD