Joshua.Lee

From: Lee.Money
Sent: 04 February 2025 11:13
To: Joshua.Lee
Subject: RE: Additional information required for planning application DC/24/1501, 13 Browns Lane, Storrington EH response 24/12/24

Hi Joshua

Thanks for the sketch and the photos'. They are very helpful.

The ASHP location is close to the bedroom window - approx. 6m and I am concerned that there will be noise impacts
The existing fence and gate may not screen the ASHP from the first floor window. It's going to be located in the access way to the garden and so that precludes putting a canopy over it as I have suggested before.

A solution is if they can move the ASHP a couple of metres further along the wall. This will increase the separation distance and reduce the noise at the neighbours first floor window. See sketch below. Alternatively we could condition it to allow to the unit only run in quiet mode at night but I don't think the cozy units have this ability.