From: FRS Water and Access [redacted]
Sent: 22 April 2025 09:25
To: Planning
Subject: Planning consultation - DC/25/0609 Little Thakeham Farm Storrington Road Thakeham West Sussex

Categories: Consultations

FAO: Halima Chowdhury

Dear Halima,

From the details provided for planning application No. DC/25/0609 for the temporary campsite open for 60 days from 18th April 2025 to 12th September 2025 and no more than 42 days consecutively; there does not appear to be a suitable access for a fire appliance to attend the site in the event of an emergency or fire situation and may not be capable of attending a fire incident. If an access road or track is to be considered, it will need to be capable of supporting 18-Tonne axial weight of a fire appliance, 3.1 metres wide through any gateway or narrowing, 3.7m between road edge or curbs and a suitable turning facility to enable a fire appliance to turn and make their exit.

Regards
Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 [redacted]
Web www.westsussex.gov.uk/fire
[redacted]
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.