

SOAKAWAY DESIGN

NEW SOAKAWAY TO BE MIN. 5m FROM BUILDING, AND BE SUBJECT TO A POROSITY TEST TO DETERMINE SIZE & DESIGN OF SOAKAWAY. DESIGN OF THIS SOAKAWAY TO BE ALSO IN ACCORDANCE WITH BRE DIGEST 365 - SOAKAWAY DESIGN, COPIES OF ALL TEST RESULTS, CALCULATIONS AND DESIGN TO BE PROVIDED TO BUILDING CONTROL FOR APPROVAL

New RWP with 8.1G to connect into new soakaway subject to Building Control Approval

New double doors and window to client specification. Glazing to have centre-pane U-value of 1.6W/m²K. Glazing to be toughened where necessary in accordance with Approved Document K. Glazing and frame to be able to withstand a lateral force of 0.74kN/m, in accordance with BS 6399: Part 1: 1996. Thermabate cavity closers to all door thresholds and reveals.

Ensure new window/door DPC laps vertical DPC

Upvc sink waste taken to 8.1G with 100mmØ drain connection to existing foul water system to BCO approval.

Existing window opening reduced in width with masonry construction to match to existing

Proprietary rooflight/roof lantern to client specification. Glazing to have centre-pane U-value of 1.6W/m²K.

Mechanical extract to new cooker hood extract to extract at a rate of 50 l/s. To terminate through proprietary wall ventilator

Existing walls to be demolished (shown dashed).

New masonry to be bonded to existing masonry using proprietary stainless steel vertical ties (Furtek or similar approved) in conjunction with an insulated vertical DPC

Steel beams and columns to Structural Engineer's design, details and specification and lined with plasterboard to achieve 30 minutes fire resistance

All steel beams/columns and walls (where shown) to receive 37.5mm Kingspan Kooltherm K18 dry-lining insulation boards to reveal to prevent thermal bridging

REFER TO STRUCTURAL ENGINEER'S DRAWINGS FOR POSITIONS AND DETAILS OF CONSTRUCTION, EXPANSION AND MOVEMENT JOINTS

Note: If any downlights are to be installed they shall be either fire rated or be fitted with fire hoods.

Kitchen

Dining

Shower room

Hall

Bedroom 4

Lounge

GROUND FLOOR PLAN - AS PROPOSED
SCALE @ 1:50 ON AN A1 SHEET

FIRST FLOOR PLAN - AS PROPOSED
SCALE @ 1:50 ON AN A1 SHEET

FRONT ELEVATION - AS PROPOSED
SCALE @ 1:100 ON AN A1 SHEET

SIDE ELEVATION - AS PROPOSED
SCALE @ 1:100 ON AN A1 SHEET

REAR ELEVATION - AS PROPOSED
SCALE @ 1:100 ON AN A1 SHEET

FOR BUILDING
REGULATION
PURPOSES ONLY
NOT FOR CONSTRUCTION

Proprietary rooflight installed in existing roof to client specification. Glazing to have centre-pane U-value of 1.6W/m²K.

Code 5 lead flashing and proprietary abutment ventilators by Nicholson Airtrak, or similar approved to be installed at abutment of new flat roof with existing roof

New SS to connect into existing extended SVP

Single ply membrane flat roof laid to falls

UPVC rainwater guttering to match the existing

Fascia and soffits to be formed in timber with a painted finish to match existing

Provide ventilation at a rate of 25,000mm²m through the use of a continuous proprietary continuous eaves ventilator. Ventilators to be designed to exclude large insects

Steel beams, lintels and joists over to structural engineer's design, details and specification and lined with plasterboard to achieve 30 minutes fire resistance

Slate tiles to external finish

Sound insulation between new floor joists to structural engineer's design, details and specification.

Dashed line indicates new handrail

Dashed line indicates new landing

Existing staircase

NOTE: ALL LEVELS TO BE CHECKED AND AGREED ON SITE

Existing foundation to be confirmed as adequate for additional loading by Structural Engineer - refer to Structural Engineer's drawings, details and specification

SECTION A-A - AS PROPOSED
SCALE @ 1:50 ON AN A1 SHEET

A	12.08.20	CS	Updated to suit BCO comments	-
REV.	DATE.	BY.	AMENDMENT.	CHK.

BUILDING
REGULATIONS

NOTES.
DO NOT SCALE OFF THIS DRAWING UNLESS FOR PLANNING PURPOSES.

CHECK ALL DIMENSIONS ON SITE BEFORE ANY WORK IS COMMENCED.

ALL GOODS MATERIALS AND WORKMANSHIP MUST CONFORM WITH CURRENT BUILDING REGULATIONS, BRITISH STANDARDS AND CODES OF PRACTICE.

COPYRIGHT OF THIS DRAWING IS RETAINED BY GEORGE BAXTER ASSOCIATES LTD. AND IT MUST NOT BE REPRODUCED WITHOUT WRITTEN CONSENT.

CLIENT
WAYNE FOSTER
07855 814426

CLIENT
MR NIGEL RAPLEY
26 HIGHLANDS AVENUE
HORSHAM
WEST SUSSEX

DRAWING
Floor Plans, Elevations and Section A-A
As Proposed

DATE: 11.11.2025 SCALE: Varies at A1 DRAWN BY: CS
CHECKED BY: RH

JOB NO. G526 DRAWING NO. BR.02 REV. A

0m 2m 4m 6m 8m 10m

VISUAL SCALE 1:100 @ A1

0m 1m 2m 3m 4m 5m

VISUAL SCALE 1:50 @ A1