[redacted]

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 05 January 2026 13:33
To: Planning
Subject: Discharge of Fire Hydrant Condition - DISC/25/0362 Kilnwood Vale Sub-Phase 3DEFG Kilnwood Vale Crawley Road Horsham Faygate

Categories: Consultations

AO: Kate Turner

Dear Kate,

Having viewed the details for the request to discharge condition 15-fire hydrants (FHs) for planning application number DISC/25/0362, providing the fire hydrants indicated on the plan submitted for this site are in place, ready for use and West Sussex Fire & Rescue Service (WSFRS) are informed they are ready for operational use the hydrant condition raised will be met and the condition discharged. The fire hydrant's locations for this site have been consulted with and agreed with Triconnex and Southern Water. Unfortunately, on too many occasions new housing estate properties are occupied prior to WSFRS being informed fire hydrants are ready for use, which then puts lives and properties at risk in the event of a fire.

Regards
Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 **Mobile** [redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his 🏳️‍🌈
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.