From: Kevin.Beer <Kevin.Beer@horsham.gov.uk>
Sent: 31 July 2024 15:01:11 UTC+01:00
To: "Amanda.Wilkes" <Amanda.Wilkes@horsham.gov.uk>
Subject: DC/24/0976 - Rikkyo School

Dear Amanda,

Thank you for consulting Environmental Health on the above planning application. We have the below comments to make.

1. No technical detail on the proposed air source heat pumps and condensers has been provided.
2. However, given that the pumps and condensers will be located in enclosures and the closest noise sensitive premises is located approximately 600m from the site of the enclosures we consider it unlikely that they will have any impact on residential amenity.

Given the above we therefore do not object to the granting of planning permission.

Kind regards

Kevin

Kevin Beer

Environmental Protection Officer

Telephone: 01403 215420
Email: Kevin.Beer@horsham.gov.uk