HORSHAM DISTRICT COUNCIL CONSULTATION

TO:	Horsham District Council – Planning Dept
LOCATION:	Geerings Dorking Road Warnham
DESCRIPTION:	
REFERENCE:	DC/25/0957
RECOMMENDATION:	~~Advice /~~ No Objection ~~/ Objection / More Information / Modification / Refusal~~
SUMMARY OF COMMENTS & RECOMMENDATION: The proposal will not harm the special interest of the listed building.	
MAIN COMMENTS: Dear Steve, As stated in the DAS there is a real problem with sourcing Horsham stone suitable for roofing. This is an ongoing problem with little hope for a suitable and sustainable source in the future. The approach of removing stone from certain roof slopes in order to maintain a full coverage on more visible slopes is not an ideal solution but in the circumstances is acceptable. I am satisfied consent can be granted in this case. Regards, Seán	
ANY RECOMMENDED CONDITIONS: N/A	
NAME:	Seán Rix
DEPARTMENT:	Conservation
DATE:	18.07.25