HORSHAM DISTRICT COUNCIL CONSULTATION

TO:	Horsham District Council – Planning Dept
LOCATION:	32 High Street, Steyning BN44 3YE
DESCRIPTION:	
REFERENCE:	DC/25/0027
RECOMMENDATION:	~~Advice /~~ No Objection ~~/ Objection / More Information / Modification / Refusal~~
SUMMARY OF COMMENTS & RECOMMENDATION: The proposed replacement of the windows in the ground floor bay is acceptable.	
MAIN COMMENTS: Dear Josh, The existing shop windows are a twentieth century installation and add nothing to the appearance of the historic building. The proposed replacements will replicate more traditional patterns of fenestration. The installation of double glazing will not be problematic in this case as long as the internal beading is a suitable colour to avoid drawing attention. I am satisfied the information provided is sufficient to avoid detailed conditions. Regards, Seán	
ANY RECOMMENDED CONDITIONS: N/A	
NAME:	Seán Rix
DEPARTMENT:	Conservation
DATE:	27.01.25