HORSHAM DISTRICT COUNCIL CONSULTATION

TO:	Horsham District Council – Planning Dept
LOCATION:	Lane End, Rectory Lane, Pulborough
DESCRIPTION:	
REFERENCE:	DC/24/0087
RECOMMENDATION:	~~Advice /~~ No Objection ~~/ Objection / More Information / Modification / Refusal~~
SUMMARY OF COMMENTS & RECOMMENDATION: The proposal will not harm the character of the conservation area.	
MAIN COMMENTS: Dear Steve, Lane End is an attractive Edwardian dwelling. The extension of the existing ancillary building will not harm the character of the conservation area. I have suggested conditions below. Regards, Seán	

ANY RECOMMENDED CONDITIONS:

LB02 Roof Detailing/Junctions

Regulatory Condition: The new roof junctions at ridge, hips, eaves and verges shall be built to reflect traditional detailing including exposed rafter feet, cut verges, bonnet hip tiles and hogs back or half round ridge tiles.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB03 Windows

Regulatory Condition: The new windows fitted in the building hereby permitted shall have timber casements flush fitted with their frames.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB04 Roof Lights

Regulatory Condition: The roof lights hereby permitted shall be metal framed and sit flush with the roof slope.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

LB05 Rainwater Goods

Regulatory Condition: All new and replacement rainwater goods shall be cast iron or cast aluminium or cast effect plastic.

Reason: To ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

NAME:	Seán Rix
DEPARTMENT:	Conservation
DATE:	16.02.24