

Risk analysis Key

- Warning - Of a residual risk that cannot be designed out
- Indication - Of a residual risk requiring compulsory action

Residual Risks

Paving slabs under ASHPs create a skid risk when condensate freezes. A concrete base and shingle surround is specified instead.

Residual risk - paving slabs not to be laid in the vicinity in the future.