To: Lee.Money
Subject: RE: DISC/23/0240 Grove House Elm Grove Lane Steyning West Sussex EH response

-----Original Message-----
From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 15 March 2023 12:12
To: Giles.Holbrook <Giles.Holbrook@horsham.gov.uk>
Subject: RE: DISC/23/0240 Grove House Elm Grove Lane Steyning West Sussex EH response

Hi Giles

Hope you are well.

I have reviewed the submissions in respect of conditions 3,4, and 6A to planning permission DC/20/0789.

For condition 3 (CEMP) the details are satisfactory and the condition can be discharged.

For condition 4 (contamination) the Stage 1 Tier 2 Site Investigation GQRA has identified that further investigation works are required to determine the extent of the contamination identified at the site and to develop the remedial strategy required by the condition. Accordingly this condition should not be discharged.

For condtion 6A(asbestos) the information provided is satsfactory and this part condition can be dicharged.

Regards

lee

Lee Money
Team Leader Environmental Protection
Telephone: 01403 215410 |
07879481032
Email:Lee.Money@horsham.gov.uk
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton