Alice.Johnson

From: Alice.Johnson
Sent: 12 February 2025 10:37
To: Alice.Johnson
Subject: FW: Planning Application Consultation - DISC/24/0312 8 Station Road Billingshurst EH response

Alice Johnson
Planning Officer

Telephone: 01403 215322 | 07585 402935
Email: Alice.Johnson@horsham.gov.uk

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

The Council will only accept service of documents by email if they are sent to legal@horsham.gov.uk. Any documents sent to individual emai
Please contact us in advance if your email, including any attachments, is going to exceed 30MB.

From: Lee.Money
Sent: Tuesday, December 24, 2024 1:11 PM
To: Alice.Johnson
Subject: RE: Planning Application Consultation - DISC/24/0312 8 Station Road Billingshurst EH response

Hi Alice

Thanks for the consultation request.

To discharge condition 5 a risk assessment is required to be submitted which sets out the frequency for sampling the system. There is also a minor typo as the statutory undertaker is Southern ater not Thames water.

To discharge condition 6 the recycled greywater scheme will need to be revised to exclude supply to the washing machine and dishwasher. The DWI technical guidance advises that water for sanitary purposes includes water used for dishwashing
and laundry must be of potable quality.

Regards and have a good Christmas

Lee

LeeMoney
Team Leader Environmental Protection

Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton