
From: FRS Water and Access [REDACTED]
Sent: 15 April 2026 16:34
To: Planning
Subject: Planning consultation - DC/25/1700 The Slips West End Lane Henfield West Sussex BN5 9RG

Categories: Consultations

FAO: Daniel Holmes

Dear Daniel,

Having viewed the plans for the planning application no. DC/25/1700 for the change of use of the land for the stationing of 4no. gypsy and traveller static caravans for residential purposes and 4no. associated dayrooms; the nearest fire hydrant for the supply of water for firefighting is 380 metres away, 205 metres further than the 175-metre distance required for a domestic premises. If an alternative supply of water for firefighting is to be considered it will need to conform with the details identified in Approved Document – B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service.

Evidence is also required to show suitable access for a fire appliance to the site; the access road capable of supporting 18-Tonne axial weight of a fire appliance, and a suitable turning facility to enable a fire appliance to turn and make their exit. The road widths for a fire appliance are given in AD-B Volume 1: B5 section 13 Table 13.1.

Regards
Ian

Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 [REDACTED]

Web www.westsussex.gov.uk/fire

Email frswaterandaccess@westsussex.gov.uk

Bognor Regis Fire Station, West Meads Drive, West Sussex, PO21 5TB

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
