

From: Sean.Rix <Sean.Rix@horsham.gov.uk>
Sent: 22 April 2026 12:44:50 UTC+01:00
To: "Halima.Chowdhury" <Halima.Chowdhury@horsham.gov.uk>; "Planning" <planning@horsham.gov.uk>
Subject: DC/26/0569 Amen Cottage, Manleys Hill, Storrington

Dear Halima,

Although I do not agree with many of the points made in the supporting documents regarding the qualities or fundamental failings of timber windows, I am satisfied the proposal to replace three windows on the secondary elevations will not harm the character of the conservation area or the interest of the historic cottage. The neighbouring property has uPVC windows fitted in the principal elevation and this has led to harm to the interest of the semi-detached pair. I would not support replacement of the timber sash windows fitted in the principal elevation but am satisfied the replacement of the three windows in the rear and side elevations is not harmful. I do not object to a positive decision being made.

Regards,
Seán

Seán Rix

Senior Conservation Officer
Specialists Team - Strategic Planning

Telephone: [01403 215276](tel:01403215276)

Email: Sean.Rix@horsham.gov.uk



Horsham District Council, Alberly House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton