Alice.Johnson

From: Lee.Money
Sent: 22 April 2025 12:25
To: Alice.Johnson
Subject: RE: Planning Application Consultation - DISC/25/0117 Oreham Manor Farm Oreham Common EH response
Attachments: ufm3_Environmental_Health_Consultation_Sheet.pdf

Hi Alice

Thanks for the consultation request.

The submitted reports are satisfactory. However, the consultant has recommend that all asbestos containing materials including roofing and cladding be removed.
I can't see that this has been confirmed in the Remediation Statement. Please can you ask them to provide copies of the consignment notes for the removal of the asbestos materials.

The consultant has also recommended that a Remediation Verification report is prepared confirming completion of the recommended remediation works. This has yet to be provided.

Regards

Lee

Lee Money
Team Leader Pollution

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

Horsham District Council

From: Planning <planning@horsham.gov.uk>
Sent: 22 April 2025 12:03
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>
Subject: Planning Application Consultation - DISC/25/0117

Please see the attached consultation letter from Horsham District Council Re:DISC/25/0117

Telephone:
Email: planning@horsham.gov.uk

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton