Registered Office:
Newington House
237 Southwark Bridge Road
London SE1 6NP

Registered in England and Wales No: 3870728

Company:
UK Power Networks
(Operations) Limited

Our Ref: 8500313548

Planning Office
Horsham District Council
Parkside
Chart Way
Horsham
West Sussex
RH12 1RL

Sent by email to
planning@horsham.gov.uk

28th December 2024

Dear Sir/Madam

Electricity Act 1989
Overhead Line (Exemption) (England & Wales) Regulations 2009
Statutory Instrument 2009 No. 640 Electricity, Paragraph 3 (1)

This notice is being given to your Council under The Overhead Lines (Exemption) (England & Wales) Regulation 2009.

Under this exemption, your Authority is required to determine, within 6 weeks of receipt of this notice, whether it is considered that the proposal is likely to have a significant adverse effect on the environment.

The works associated with this proposal will commence on site on or after the expiry of the required six weeks notice, unless it becomes necessary to apply to the Secretary of State for Trade and Industry for his consent.

Particulars of proposal:

Location: Land at Sedgwick Lane, Horsham RH13 6QE

Plan No: UKPN8500313548 1-500

Details of proposal:

- To remove the existing 50kVA pole mounted transformer (pmt) from pole 619159
- To install a new 100kVA pmt on pole 619159

Yours faithfully

[redacted]

Stessie Aristide
Connections Surveyor
South Eastern Power Networks plc
07935 085579
stessie.aristide@ukpowernetworks.co.uk

Return Address:
South Eastern Power Networks plc
Property & Consents
c/o Energy House
Hazelwick Avenue
Three Bridges
Crawley
RH10 1EX