

Jacques.Burrowes

From: Lee.Money
Sent: 07 April 2026 15:53
To: Jacques.Burrowes
Subject: RE: DC/26/0428 Spring Copse Business Park Stane Street Slinfold EH response

Hi Jacques

Thanks for the consultation request.

The lighting scheme looks OK but I'm a bit concerned that the light closest to Mead Cottage will come on at 05:00. In the winter there will be minimal tree cover screen the light. Is it possible that this light can come on after 06:00am? Also is the site in use 7days a week? The lighting should not operate if the site is not in use.

If the application is approved I would recommend that the following conditions are attached:

1. The lighting installation hereby approved shall operate between 05:00 hours and 20:00 hours only.
2. The lighting installation hereby approved shall be installed in accordance with the recommendations, details and specifications set out in the Lighting Assessment reference 250285-LTBL-REP-001 revision P01 and dated 19.09.2025.
3. Before commencement of operation of the approved lighting scheme the applicant shall appoint a suitably qualified member of the institute of lighting professionals (ILP) to validate that the lighting scheme as installed conforms to the recommendations for environmental zone E2 in the ILP document "Guidance Notes for the Reduction of Obtrusive Light GN01-21. The validation report shall be submitted to and approved by the local planning authority and the approved details and attenuation measures shall be permanently retained and maintained in working order for the duration of the use and their operation.

[REDACTED]

[REDACTED]

Lee Money

Team Leader Pollution

[REDACTED] | [REDACTED]

[REDACTED] [REDACTED]



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton



From: Planning <planning@horsham.gov.uk>
Sent: 24 March 2026 11:43
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>
Subject: Planning Application Consultation - DC/26/0428

Please see the attached consultation letter from Horsham District Council Re:DC/26/0428

Telephone:

Email: planning@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton