From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 03 September 2025 12:06:39 UTC+01:00
To: "Planning" <planning@horsham.gov.uk>
Subject: Hydrant condition - DC/25/0439 Morelands Barn Naldretts Lane Rudgwick West Sussex RH12 3BU
Attachments: HC - DC.25.0439 Morelands Barn, Naldretts Lane, Rudgwick, RH12 3BU.docx
Categories: Consultations

FAO: Bethan Tinning

Dear Bethan,

Please find attached a planning condition for application no. DC/25/0439 for the requirement of an additional fire hydrant. Currently the nearest Hydrant to these proposed properties is 430 metres away. The supply of water for firefighting for a domestic premises should be within 175 metres. If an alternative water supply for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service.

Regards
Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 **Mobile** 07921 291051
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.