From: Sean.Rix
Sent: 24 July 2025 11:25
To: Shazia Penne; Planning
Subject: DISC/25/0215 Aquarius, The Street, Bramber

Categories: Consultations

Dear Shazia,

I am satisfied the timber boarding is acceptable.

The concrete roof tile is not acceptable. The roof tiles should be clay with a double camber.

The roof window is not acceptable. The model shown has a timber frame. The Velux Heritage Conservation model will be acceptable. Or any other metal framed model from other companies.

Regards,
Seán

Seán Rix
Senior Conservation Officer
Specialists Team - Strategic Planning

[redacted]

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton