

From: Lee.Money <Lee.Money@horsham.gov.uk>
Sent: 08 October 2026 13:33:41 UTC+01:00
To: "Nicola.Pettifer" <Nicola.Pettifer@horsham.gov.uk>
Subject: RE: DISC/26/0267 New Place Nurseries London Road Pulborough West Sussex EnvH response

Hi Nic

Following on from my previous email I have now reviewed the 7kW heat pump installs for plots 17-18 and 154-155. My concern was the siting of these units close to each other could give rise to cumulative noise impacts. Having reviewed the manufacturers noise data I am satisfied that it is unlikely there would be significant adverse noise impacts from the location of the ASHPs.

Regards

Lee

Lee Money

Team Leader Pollution

Telephone: 01403 215410 | 07879 481032

Email: Lee.Money@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton



From: Nicola.Pettifer <Nicola.Pettifer@horsham.gov.uk>
Sent: 24 September 2026 12:29
To: Lee.Money <Lee.Money@horsham.gov.uk>
Subject: RE: DISC/26/0267 New Place Nurseries London Road Pulborough West Sussex EnvH response

Hi Lee

I'll raise a consultation through Uniform so that it's logged.

I know you're under pressure with Kevin out at the moment, but if you have got a few spare moments to have a look at the following ASHP info, that would be super appreciated.

The agent has come back with the following on the ASHP:

In regard to the plots noted, the kW's are as follows. We've spoken to Valiant who have confirmed that the impact with two ASHPs nearby is expected to increase noise by a maximum of 1 decibel which is not noticeable.

7-10: 3.5kW / each
11-13: 3.5kW / each
17-18: 7kW / each
53-56: 3.5kW / each
63-64: 3.5kW / each
87-94: 3.5kW / each
97-98: 3.5kW / each
107-112: 3.5kW / each
137-144: 3.5kW / each
148-151: 3.5kW / each
154-155: 7kW / each

thanks

Nic

Nicola Pettifer

Senior Planning

Telephone: [01403 215238](tel:01403215238)

Email: Nicola.Pettifer@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

Horsham District Council will only accept service of documents by email if they are sent to legal@horsham.gov.uk. Any documents sent to individual email addresses will not be accepted under any circumstances.

Communications received after 5pm will be regarded as being served on the next working day.
Please contact us in advance if your email, including any attachments, is going to exceed 30MB.

From: Lee.Money <Lee.Money@horsham.gov.uk>

Sent: 11 September 2026 11:13

To: Nicola.Pettifer <Nicola.Pettifer@horsham.gov.uk>


Subject: RE: DISC/26/0267 New Place Nurseries London Road Pulborough West Sussex EnvH response

Hi Nic

Thanks for the consultation request

With regard to the heat pump locations there a few of the plots where 2 units are located close together and this will increase the potential cumulative noise impacts. The Aerotherm ASHP's are relatively quiet so I don't think this is a big issue for the smaller capacity units. Please could you ask them to confirm the capacity of the ASHPs to be installed at the following plots as shown on the H9376-GPA-XX-XX-DR-UD-203018-C05- Air Source Heat Pump Plan and extract below:

7-10
11-13
17-18
53-56
63-64
87-94
97-98
107-112
137-144
148-151
154-155



Lee

Lee Money

Team Leader Pollution

Telephone: [01403 215410](tel:01403215410) | [07879 481032](tel:07879481032)

Email: Lee.Money@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton



From: Lee.Money <Lee.Money@horsham.gov.uk>

Sent: 28 August 2026 15:26

To: Lee.Money <Lee.Money@horsham.gov.uk>

Subject: FW: Planning Application Consultation - DISC/26/0267 New Place Nurseries London Road Pulborough West Sussex

Approval of details reserved by conditions 8 (external materials) and 9 (ASHP details) to approved application DC/24/1676

Lee Money

Team Leader Pollution

Telephone: [01403 215410](tel:01403215410) | [07879 481032](tel:07879481032)

Email: Lee.Money@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton



From: Planning <planning@horsham.gov.uk>

Sent: 25 August 2026 11:18

To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>

Subject: Planning Application Consultation - DISC/26/0267

Please see the attached consultation letter from Horsham District Council

Re:DISC/26/0267

Telephone:

Email: planning@horsham.gov.uk



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB

Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton